

50. MEĐUNARODNI KONGRES KGH, BEOGRAD 05.12.2018.



RELa**TED**



Beogradske elektrane
BELGRADE PUBLIC UTILITY COMPANY

Konverzija mreže daljinskog grejanja u niskotemperaturske sa povećanom upotrebom lokalnih solarnih sistema, u skladu sa programom Horizon 2020 – projekat Related.

Ljubiša Vladić, Radmilo Savic
JKP “Beogradske elektrane”



This project has received funding from the European Union's Horizon 2020 research and innovation programme under grant agreement No 768567

Uvod


- Projekat RElated (REnewable Low TEMperature District) je zajednička inicijativa 14 kompanija i istraživačkih ustanova širom Evrope
- Projekat se finansira sredstvima EU iz istraživačkog fonda Horizon 2020
- Fokus je na daljinskom grejanju (DG) kao energetske najefikasnijem sistemu za grejanje gradova i koji ima ključnu ulogu u smanjenu emisije CO2 u Evropi.
- Projekat RElated će se realizovati u 4 gradova:
 - Vinge, Danska
 - Tartu, Estonija
 - **BELGRADE, Srbija**
 - Iurreta, Španija

RELaTED koncept


- Razvijanje ultra niske temperaturne mreže (ULT) u sistemu DG ($\sim 45^{\circ}\text{C}$)
- Integrisanje obnovljivih i otpadnih izvora toplote u sistem DG
- Smanjenje operativnih troškova usled manjih toplotnih gubitaka
- Veća energetska efikasnost toplotnih izvora
- Razvijanje sledećih tehnologija:
 - Building Integrated Low Temperature Solar Thermal Systems (BILTST)
 - Triple Function Substations (3FS)
 - District Heating connected Reversible Heat Pump (DHRHP)

Nova tehnologija – 3F trofunkcionalna PS


- Preuzima TE iz mreže DG
- Dodaje TE više temperature u razvodni vod DG
- Vraća TE niže temperature u povratni vod DG



RELaTED koncept



RELaTED koncept



Tipični temperaturni režimi u mreži DG i zahtev za ULT u ovom projektu:



- DH High Temperature System (HT), 100/50 °C ; 90/70 °C ; System type: Radiators
- DH Low Temperature System (LT), 80/40 °C ; 70/50 °C ; System type: Radiators
- DH Very Low Temperature System (VLT), 60/30 °C ; 55/35 °C ; System type: Radiators
- **DH Ultra Low Temperature System (ULT), 45/35 °C ; 35/30 °C ; System type: Floor heating**

Demo lokacija Beograd, Srbija



- JKP “Beogradske elektrane” – osnovane - 1965.
- Broj toplotnih izvora 48
- Instalisani kapacitet 3.000 MW
- Dužina trasa 730km
- Broj podstanica 8.800
- Grejana površina objekata 22.000.000 m²
- Broj priključenih stanova 330,000
- Godišnja proizvodnja 3,000 GWh
- 51% Beograda je povezano na daljinski sistem






Aktivnosti i ciljevi projekta RElated

- **Demo lokacija 1: PS Vinogradski Venac 36 za 5 stambenih zgrada**
 - **Smanjenje temperature u sekundarnoj mreži** – rekonstrukcija PS
 - Razdvajanje merenje potrošnje TE grejanja i PTV za svaku zgradu posebno


- **Demo lokacijae 2: PS Borova 8 – OŠ Ujedinjene nacije**
 - **Implementacija solarnog sistema u sistem DG**
 - Primena 2F PS
 - Postavljanje solarnih kolektora na krov zgrade (70m², max 90KW)

Demo lokacija 1: PS Vinogradski Venac 36





Subsystem	Power [kW]
Radiators	1.105
DHW	274
TOTAL	1380




Operation conditions heating	Primary circuit	Secondary circuit
	District heating side	Radiators heating
Tsupply [C]	120	80
Treturn [C]	65	60
Nominal flow [m3/h]	18,07	62


Operation conditions DHW	Primary circuit	Secondary circuit
	District heating side	DHW
Tsupply [C]	65	50
Treturn [C]	22	10
Nominal flow [m3/h]	5,61	7,8

Izvršena je analiza potrebne energije za svaku zgradu


Vinogradski Venac 29




Vinogradski Venac 31




Vinogradski Venac 40



Vinogradski Venac 36




Vinogradski Venac 38



Demo lokacija 2 - PS Borova 8 – OŠ Ujedinjene nacije



Postojeća šema PS




Subsystem	Power [kW]
Radiators	550
Air heating	400
DHW	140


Concept	Primary circuit	Secondary circuit
	District heating side	Radiators heating
Tsupply [C]	120	80
Treturn [C]	65	60
Nominal flow [m3/h]	8,8	30,1

Concept	Primary circuit	Secondary circuit
	District heating side	Air heating
Tsupply [C]	120	80
Treturn [C]	65	60
Nominal flow [m3/h]	6,4	20

Concept	Primary circuit	Secondary circuit
	District heating side	DHW
Tsupply [C]	65	50
Treturn [C]	22	10
Nominal flow [m3/h]	1,62	2



Šema nove 2F PS





Beogradske elektrane

BELGRADE PUBLIC UTILITY COMPANY



REL_aTED

HVALA NA PAŽNJI

dr Ljubiša Vladić, dipl.inž.maš.

ljubisa.vladic@bgdel.rs

dr Radmilo Savić, dipl.inž.maš.

radmilo.savic@bgdel.rs



This project has received funding from the European Union's Horizon 2020 research and innovation programme under grant agreement No 768567